

# Analysis instrument for determining the concentration of SO<sub>2</sub> in SF<sub>6</sub> gas Model GA25

WIKA data sheet SP 62.04

## SF<sub>6</sub> Aciditor

## **Applications**

Measurement of the concentration of  $SO_2$  in  $SF_6$  gas-filled equipment

#### **Special features**

- Fast test results, measurement duration approx. 2 minutes
- Compact and low weight
- Maintenance-free
- Operation via touchscreen
- Long battery life



Analysis instrument, model GA25

### Description

The model GA25 analysis instrument is a cost-effective solution for determining the concentration of SO<sub>2</sub> in SF<sub>6</sub> gas-filled equipment. The concentration of SO<sub>2</sub> is an indicator for the presence of decomposition products in SF<sub>6</sub> gas.

#### Easy to use

The advantage of the GA25 over conventional single-use test-tubes lies in the reproducibility of the measured value and the simple operation. The electrochemical sensor can, after a service life of 24 months, be replaced by the operator.

#### Fast and safe

The GA25 was developed for the fast and accurate measurement of  $SO_2$  (Sulphur Dioxide). With its automatic pressure and flow control, the measurement is reproducible and erroneous measurement is thus eliminated. During the measurement, the determined concentration can be read directly from the touchscreen.

#### WIKA data sheet SP 62.04 · 04/2013

Data sheets showing similar products and accessories: Portable SF6 gas transfer unit model GTU-10, see data sheet SP 63.07 Gas recovery bag, model GA45; see data sheet SP 62.08

#### **Environmentally friendly**

The test gas can be temporarily collected at the outlet of the GA25 with a gas-recovery bag so that the environmentally-hazardous  $SF_6$  gas does not escape into the surrounding atmosphere.

Once the recovery bag is full, the  $SF_6$  gas can be pumped back into a gas cylinder using a model GTU-10 gas transfer unit and subsequently recycled or, depending on the gas quality, be reused directly.





Measuring principle Electrochemical SO<sub>2</sub> sensor

#### Measuring range

0 ... 10 ppm<sub>v</sub> 0 ... 20 ppm<sub>v</sub> 0 ... 100 ppm<sub>v</sub> 0 ... 500 ppm<sub>v</sub>

#### Accuracy

#### Resolution

Maximum zero-point drift

 $0.1 \text{ ppm}_{v}$ 

Long-term stability < 1 % signal degradation/month (linear) < 0.5 % at measuring range 0 ... 500 ppm<sub>v</sub>

Flow rate 20 litres/ hour

Gas consumption approx. 0.7 litres per measurement (under atmospheric pressure)

#### Inlet pressure

0.5 ... 35 bar (gaseous) With automatic flow control

Control panels Input via touchscreen

The 'Purge' button conducts the contents of the 4-metre-long measuring tube directly to the outlet. This should be carried out before each measurement.

**Display** Touchscreen (240 x 128 pixel)

#### Voltage supply

Lithium-ion accumulator for approx. 10 h operating time Charger: AC 100 ... 265 V, 50/60 Hz

#### Permissible temperatures

Storage: -10 ... +60 °C Operation: 0 ... +50 °C

# Permissible humidity

 $\leq$  90 % r. h. (non-condensing)

**Dimensions** W x H x D: 280 x 140 x 300 mm

Weight approx. 6 kg

Service life of the SO<sub>2</sub> sensor 2 years after installation

# Accessories

	Designation	Order pe
	Designation	Order no.
C i	Adapter, measuring hose to DN 8	14017515
0	Adapter, measuring hose to DN 20	14013758
My Market	Gas recovery bag, model GA45 For specifications see data sheet SP 62.08	14013015
-0	Inlet pressure control unit for gas analysis instruments Model GA05	14050089



Ordering information Model / Measuring range / Accessories

© 2013 WIKA Alexander Wiegand SE & Co. KG, all rights reserved. The specifications given in this document represent the state of engineering at the time of publishing. We reserve the right to make modifications to the specifications and materials.

WIKA data sheet SP 62.04 · 04/2013

Page 3 of 3



WIKA Alexander Wiegand SE & Co. KG Alexander-Wiegand-Straße 30 63911 Klingenberg/Germany Tel. (+49) 9372/132-0 Fax (+49) 9372/132-406 E-mail info@wika.de www.wika.de